



NOTES:

- 1) CONCRETE SHALL BE CLASS 3000.
- 2) CHANNELS SHALL BE CONSTRUCTED TO PROVIDE SMOOTH SLOPES AND RADII TO OUTLET PIPE.
- 3) ALL RIDGED CONNECTING PIPES SHALL HAVE A FLEXIBLE JOINT WITHIN 18" OF MH WALL
- 4) BASES MAY BE PRECAST OR POURED IN PLACE.



**DETAIL FOR
STANDARD MANHOLE
BASE SECTION**

DATE: AUGUST 2009

DRAWING NO. 14